



**City of Bishopville, Inc. (SC3110001)**  
**2025 Annual Drinking Water Quality Report**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our source for water is wells. Our wells draw from the Middendorf Aquifer.

Our raw water sources are most susceptible to contamination from runoff or environmental conditions, contact JT Tolson or Freddie DuBose at 803-484-5948 to decide to review this document.

I'm pleased to report that our drinking water is safe and meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact JT Tolson or Freddie DuBose at 803-484-5948. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are normally held on the first Tuesday of each month at 5:30 p.m. at the Colclough Memorial building on East Council Street.

The City of Bishopville routinely monitors constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2025, unless otherwise noted. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some small amounts of constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (µg/l)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Action Level (AL)** - the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**Action Level Goal (ALG):** *The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.*

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MCLG** - *Maximum Contaminant Level Goal* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL** - *Maximum Contaminant Level* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

**Test Results**  
**City of Bishopville, Inc.**  
**SC3110001**

**Lead and Copper – Inorganic Contaminants**

Contaminants	MCLG	Action Level	90 <sup>th</sup> percentile	# Samples over AL	Violation	Sample Date	Typical Source
Copper (ppm)	1.3	1.3	0.65 Range 0.0014- 2.3	1	No	2024	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead (ppb)	0	15	2.20 Range 0 - 11	0	No	2024	Corrosion of household plumbing systems. Erosion of natural deposits.

**Disinfectant and Disinfection By-Products**

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect in Your Water	Range	Violation	Sample Date	Typical Source
Chlorine (ppm)	4	4	1.0	0.53-1.46	No	2025	Water additive used to control microbes
HAAs [Haloacetic Acids] (HAA5) (ppb)	No goal for the total	60	3	2.6-2.6	No	2025	By-product of drinking water chlorination.
TTHMs [Total Trihalomethanes] (ppb)	No goal for the total	80	12	12-12	No	2025	By-product of drinking water disinfection.

**Chemical Constituents**

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect in Your Water	Range	Violation	Sample Date	Typical Source
Nitrate (ppm)	10	10	0.28	0.074-0.28	No	2025	Runoff from fertilizer use. Erosion of natural deposits.
Sodium (ppm) [unregulated]	NA	NA	31	2.3-31	No	2024	Naturally occurring.

Radioactive contaminants	MCLG	MCL	Highest Level Detected	Range of Levels Detected	Violation	Collection Date	Likely Source of Contamination
Combined Radium 226/228 (pCi/L)	0	5	2.0	0.717-2.0	N	2024	Erosion of natural deposits

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water is safe at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Bishopville is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. A lead service line inventory was completed throughout our system, in 2024. For more information on this inventory please contact us at 803-484-5948. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the City of Bishopville at 803-484-5948. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions. We at the City of Bishopville, work continuously to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.